



# City of Alamogordo



Engineering Department □ 1376 E. Ninth Street □ Alamogordo, New Mexico 88310 □ Ph (575) 439-4220 FAX (575) 439-4343

June 13, 2017

To: All Bidders/Plan Holders

Re: **Addendum No. 1**  
**Public Works Bid No. 2017-006**  
**Zoo Perimeter Fence**

Addendum Number 1 is issued to provide changes and/or clarifications to the above referenced Public Works Bid as per the following:

Attached is the Pre-Bid Meeting sign in sheet.

Questions:

- 1) Are the existing footings to be removed? If so, are the voids to be backfilled?  
*The footing should be removed and the voids backfilled with soil.*
- 2) Is material testing required? If so, what is the frequency?  
*The concrete will need to be tested every 150 cubic yards. Terracon is the City's on-call consultant for quality assurance testing.*

All other provisions of the Contract Documents shall remain unchanged. This addendum is hereby made part of the Contract Documents to the same extent as though contained in the original documents and itemized listings thereof. Each bidder is required to acknowledge receipt of each addendum in Section 3 of the Bid Proposal, failure to do so could render the bid non-responsive.

Plan holders: As a courtesy, please fill out the information below and fax this page back to the City of Alamogordo, Attention: Barbara Pyeatt, Purchasing Manager at 575-439-4117 or replying via e-mail to: [bpyeatt@ci.alamogordo.nm.us](mailto:bpyeatt@ci.alamogordo.nm.us)

Received By (Company): \_\_\_\_\_

Date Received: \_\_\_\_\_

Number of sheets received: \_\_\_\_\_

Time Received: \_\_\_\_\_

Signature: \_\_\_\_\_

**Public Works Bid No. 2017-006**  
**Zoo Perimeter Fence**  
**Pre-Bid Meeting (non-mandatory)**  
 June 7, 2017  
 SIGN IN SHEET

NAME	ORGANIZATION	CONTACT INFO
Nancy Beshaler	CoA - Engineering	575.439.4230
Bud Wisner	CoA - Zoo	575.439.4198
Joel Daultey	Presbys	575-439-6537
Clement Colleges	American Tradition	575-430-3602