

Daily Water Update for Monday, May 15, 2017

The 7 day average usage is 4.69 MGD which represents 37.1 days of raw water storage

La Luz Reservoirs

	5/15/17			5/14/17			Gain/Loss (ft)
	(ft)	Inventory(MG)	% Capacity	(ft)	Inventory(MG)	% Capacity	
East Reservoir:	27.78	96.59	90.67	27.71	96.28	90.37	0.07
South Reservoir:	25.36	38.30	94.96	25.44	38.44	95.31	-0.08
North Reservoir:	25.87	39.21	97.20	25.97	39.38	97.65	-0.10
Total Storage: (MG)	174.09			174.10			- 0.00
Total Capacity %	93.0			93.0			

Flow into La Luz Reservoirs

	Status	5/15/17	5/14/17	MGD
Well 5	OFF	431718	431718	0.00
Bonito	O.O.S.	101202	101202	0.00
La Luz / Fresno	ON	1484246900	1482333400	1.91
Net Total:				- 0.55

Filter Plant Production

	Status	5/15/17	5/14/17	MGD
LLWTP Production:	ON	905740	905494	2.46
AWTP Production:	ON	696756	695908	0.85
Filter Plant Production Total:				3.31

Well Production

	Status	5/15/17	5/14/17	MGD
Well 2	ON	110561	109808	0.75
Well 3	OFF	3328	3328	0.00
Well 4	OFF	249357	249357	0.00
Well 6	OFF	591350	591350	0.00
Well 7	OFF	307851	307851	0.00
Well 8	OFF	146354	146354	0.00
Prather	ON	246505	246136	0.37
Golf Course	OFF	40344576	40344576	0.00
Well Production Total:				1.12

HAFB Diversion

	Status	5/15/17	5/14/17	MGD
HAFB Meter	O.O.S.	329859	329859	0.00

Total Consumption

COA + HAFB Daily Consumption	4.43
HAFB Daily Consumption:	0.00
COA Daily Consumption For Monday, May 15, 2017	4.43
COA Daily Consumption For Monday, May 16, 2016	3.81
COA Daily Consumption is UP from this day last year	↑ + 0.62

Weather

Total Precipitation for Monday, May 15, 2017 **0.00 in**

Temperatures: High temperature: 86 °F Average high temperature: 85 °F
Low temperature: 59 °F Average low temperature: 53 °F