

Purchasing Department 2600 N Florida Alamogordo NM 88310 (575)439-4116 Fax (575) 439-4117

September 27, 2017

Addendum No. One

IFB 2017-10 Upgrade & Replacement HVAC Unit at Sgt. Willie Estrada Memorial Civic Center

Attention: Prospective Bidders

Each bidder shall acknowledge receipt of this addendum No. One (1) by including the acknowledgement form in the Bid Proposal

Addendum No. One (1) is issued to provide changes and/or clarifications to questions asked on the above referenced bid.

Change: Proposal due date has changed to Friday October 6, 2017. Time and location remain unchanged

Question: Please indicate what voltage & phase the electrical is on the existing HVAC unit.

Answer: voltage 208 and 3 phase.

All other provisions of the Contract Documents shall remain unchanged. This addendum is hereby made part of the Contract Documents. Each bidder shall acknowledge receipt of this Addendum Number One (1) using this acknowledgement page and submit with the Bid proposal.

Thank you,

Barbara Pyeatt
Chief Procurement Officer
bpyeatt@ci.alamogordo.nm.us

ADDENDUM ACKNOWLEDGEMENT

ADDENDUM NO. 1

**IFB NO. 2017-10 Upgrade & Replacement HVAC Unit at Sgt. Willie Estrada
Memorial Civic Center**

Received By: _____

Date Received: _____

Business Name: _____

Name: _____

Signature: _____

